



Indoor Luminaire Photometric Data

Description Information

Luminary Name: 55252		Lum. Catalog:	Test ID:
Lamp Name:		Lamp Catalog:	Test Date: 2020/06/03
Manufacture:		Shld. Ang(°):	Test Machine:GON-2000
Test Lab:		Frequency (Hz):	Lamp CCT(K): 3000 Ra:
Lum. Size(W*L*H):0.050m*-0.050m*0.000m		Lum. Area(m2):0.002	Lum. W(kg): 0.000
Test System: C, γ	Test Step: C=30.0 γ=1.0	Temp. (°C): 25	Humidity(%):


Character Parameter

Lamp Speciality Parameter	Luminaire Speciality Parameter	
Rated Flux(lm): 147.050	Luminary Flux(lm): 147.047	Field Angle(10%Imax): 35.5(°)
Rated Power(W):	Luminary Efficiency: 100.00%	Down Lumens&Percent: 146.715lm 99.77%
Rated Voltage(V): 24	Luminary EER(lm/W): 49.729	Up Lumens&Percent: 0.333lm 0.23%
Tested Power(W): 2.957	Max. Candela(cd): 984.407	S/MH: C0_a180=0.337 C90_270=0.334
Lamps' Inside: 1	Max Cand@Ang. (°): C=0.0 γ=1.0	CIE Type: Semi-Direct
Tested Electrics(V, A, pf):24.0, 0.123	Beam Angle(50%Imax): 19.4(°)	ErP Φuse(90°): 143.118lm
Lamp Size(W*L*H):0.050m*-0.050m*0.000m	Left=-9.1°, Right=10.3°	IRF(%): 1392.882



2D Plane Light Intensity Distribution Curve


Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03



3D Light Intensity Distribution Modal

Lum. Name:55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date:2020/06/03

3D Light Intensity Distribution Modal



Curves:

View Angles:

3D Model

Orient:0

Fixture

Tilt:0

Vert. HUD

Roll:0

Hori. HUD

Spin:0

Zonal Flux Tabulation


Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.92	0.92	0.63	0.63	47.0-48.0	0.31	143.95	0.21	97.89
1.0-2.0	2.73	3.65	1.85	2.48	48.0-49.0	0.29	144.24	0.20	98.09
2.0-3.0	4.45	8.09	3.02	5.50	49.0-50.0	0.28	144.51	0.19	98.28
3.0-4.0	6.01	14.11	4.09	9.59	50.0-51.0	0.26	144.77	0.18	98.45
4.0-5.0	7.35	21.45	5.00	14.59	51.0-52.0	0.24	145.01	0.16	98.61
5.0-6.0	8.38	29.83	5.70	20.29	52.0-53.0	0.22	145.24	0.15	98.77
6.0-7.0	9.07	38.91	6.17	26.46	53.0-54.0	0.21	145.44	0.14	98.91
7.0-8.0	9.41	48.31	6.40	32.86	54.0-55.0	0.19	145.63	0.13	99.03
8.0-9.0	9.39	57.71	6.39	39.24	55.0-56.0	0.17	145.80	0.12	99.15
9.0-10.0	9.07	66.78	6.17	45.41	56.0-57.0	0.15	145.95	0.11	99.25
10.0-11.0	8.51	75.29	5.78	51.20	57.0-58.0	0.14	146.09	0.09	99.35
11.0-12.0	7.77	83.06	5.29	56.48	58.0-59.0	0.12	146.22	0.08	99.43
12.0-13.0	6.95	90.01	4.73	61.21	59.0-60.0	0.11	146.32	0.07	99.51
13.0-14.0	6.13	96.14	4.17	65.38	60.0-61.0	0.09	146.42	0.06	99.57
14.0-15.0	5.34	101.48	3.63	69.01	61.0-62.0	0.08	146.49	0.05	99.62
15.0-16.0	4.63	106.11	3.15	72.16	62.0-63.0	0.07	146.56	0.04	99.67
16.0-17.0	4.00	110.11	2.72	74.88	63.0-64.0	0.05	146.61	0.04	99.70
17.0-18.0	3.44	113.55	2.34	77.22	64.0-65.0	0.04	146.65	0.03	99.73
18.0-19.0	2.97	116.52	2.02	79.24	65.0-66.0	0.03	146.68	0.02	99.75
19.0-20.0	2.59	119.11	1.76	81.00	66.0-67.0	0.02	146.70	0.01	99.76
20.0-21.0	2.27	121.38	1.55	82.55	67.0-68.0	0.01	146.71	0.01	99.77
21.0-22.0	2.02	123.40	1.37	83.92	68.0-69.0	0.00	146.71	0.00	99.77
22.0-23.0	1.81	125.22	1.23	85.15	69.0-70.0	0.00	146.71	0.00	99.77
23.0-24.0	1.64	126.86	1.11	86.27	70.0-71.0	0.00	146.71	0.00	99.77
24.0-25.0	1.49	128.34	1.01	87.28	71.0-72.0	0.00	146.71	0.00	99.77
25.0-26.0	1.36	129.70	0.92	88.20	72.0-73.0	0.00	146.71	0.00	99.77
26.0-27.0	1.24	130.94	0.84	89.04	73.0-74.0	0.00	146.71	0.00	99.77
27.0-28.0	1.14	132.08	0.77	89.82	74.0-75.0	0.00	146.71	0.00	99.77
28.0-29.0	1.05	133.13	0.71	90.53	75.0-76.0	0.00	146.71	0.00	99.77
29.0-30.0	0.97	134.10	0.66	91.19	76.0-77.0	0.00	146.71	0.00	99.77
30.0-31.0	0.90	135.00	0.61	91.81	77.0-78.0	0.00	146.71	0.00	99.77
31.0-32.0	0.84	135.84	0.57	92.38	78.0-79.0	0.00	146.71	0.00	99.77
32.0-33.0	0.78	136.62	0.53	92.91	79.0-80.0	0.00	146.71	0.00	99.77
33.0-34.0	0.73	137.36	0.50	93.41	80.0-81.0	0.00	146.71	0.00	99.77
34.0-35.0	0.68	138.04	0.46	93.87	81.0-82.0	0.00	146.71	0.00	99.77
35.0-36.0	0.64	138.68	0.43	94.31	82.0-83.0	0.00	146.71	0.00	99.77
36.0-37.0	0.60	139.27	0.41	94.71	83.0-84.0	0.00	146.71	0.00	99.77
37.0-38.0	0.56	139.83	0.38	95.09	84.0-85.0	0.00	146.71	0.00	99.77
38.0-39.0	0.53	140.36	0.36	95.45	85.0-86.0	0.00	146.71	0.00	99.77
39.0-40.0	0.50	140.86	0.34	95.79	86.0-87.0	0.00	146.71	0.00	99.77
40.0-41.0	0.47	141.32	0.32	96.11	87.0-88.0	0.00	146.71	0.00	99.77
41.0-42.0	0.44	141.77	0.30	96.41	88.0-89.0	0.00	146.71	0.00	99.77
42.0-43.0	0.42	142.18	0.28	96.69	89.0-90.0	0.00	146.71	0.00	99.77
43.0-44.0	0.39	142.58	0.27	96.96	90.0-91.0	0.00	146.71	0.00	99.77
44.0-45.0	0.37	142.95	0.25	97.21	91.0-92.0	0.00	146.71	0.00	99.77
45.0-46.0	0.35	143.30	0.24	97.45	92.0-93.0	0.00	146.71	0.00	99.77
46.0-47.0	0.33	143.63	0.23	97.68	93.0-94.0	0.00	146.71	0.00	99.77

Zonal Flux Tabulation - (Cont.)

Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.00	146.71	0.00	99.77	141.0-142.0	0.00	146.71	0.00	99.77
95.0-96.0	0.00	146.71	0.00	99.77	142.0-143.0	0.00	146.71	0.00	99.77
96.0-97.0	0.00	146.71	0.00	99.77	143.0-144.0	0.00	146.71	0.00	99.77
97.0-98.0	0.00	146.71	0.00	99.77	144.0-145.0	0.00	146.71	0.00	99.77
98.0-99.0	0.00	146.71	0.00	99.77	145.0-146.0	0.00	146.71	0.00	99.77
99.0-100.0	0.00	146.71	0.00	99.77	146.0-147.0	0.00	146.71	0.00	99.77
100.0-101.0	0.00	146.71	0.00	99.77	147.0-148.0	0.00	146.71	0.00	99.77
101.0-102.0	0.00	146.71	0.00	99.77	148.0-149.0	0.00	146.71	0.00	99.77
102.0-103.0	0.00	146.71	0.00	99.77	149.0-150.0	0.00	146.71	0.00	99.77
103.0-104.0	0.00	146.71	0.00	99.77	150.0-151.0	0.00	146.72	0.00	99.77
104.0-105.0	0.00	146.71	0.00	99.77	151.0-152.0	0.00	146.72	0.00	99.77
105.0-106.0	0.00	146.71	0.00	99.77	152.0-153.0	0.00	146.72	0.00	99.78
106.0-107.0	0.00	146.71	0.00	99.77	153.0-154.0	0.01	146.73	0.00	99.78
107.0-108.0	0.00	146.71	0.00	99.77	154.0-155.0	0.01	146.74	0.01	99.79
108.0-109.0	0.00	146.71	0.00	99.77	155.0-156.0	0.01	146.75	0.01	99.80
109.0-110.0	0.00	146.71	0.00	99.77	156.0-157.0	0.01	146.77	0.01	99.81
110.0-111.0	0.00	146.71	0.00	99.77	157.0-158.0	0.02	146.78	0.01	99.82
111.0-112.0	0.00	146.71	0.00	99.77	158.0-159.0	0.02	146.80	0.01	99.83
112.0-113.0	0.00	146.71	0.00	99.77	159.0-160.0	0.02	146.82	0.01	99.84
113.0-114.0	0.00	146.71	0.00	99.77	160.0-161.0	0.02	146.84	0.01	99.85
114.0-115.0	0.00	146.71	0.00	99.77	161.0-162.0	0.02	146.86	0.01	99.87
115.0-116.0	0.00	146.71	0.00	99.77	162.0-163.0	0.02	146.87	0.01	99.88
116.0-117.0	0.00	146.71	0.00	99.77	163.0-164.0	0.02	146.89	0.01	99.89
117.0-118.0	0.00	146.71	0.00	99.77	164.0-165.0	0.02	146.91	0.01	99.91
118.0-119.0	0.00	146.71	0.00	99.77	165.0-166.0	0.02	146.93	0.01	99.92
119.0-120.0	0.00	146.71	0.00	99.77	166.0-167.0	0.02	146.95	0.01	99.93
120.0-121.0	0.00	146.71	0.00	99.77	167.0-168.0	0.02	146.96	0.01	99.94
121.0-122.0	0.00	146.71	0.00	99.77	168.0-169.0	0.01	146.98	0.01	99.95
122.0-123.0	0.00	146.71	0.00	99.77	169.0-170.0	0.01	146.99	0.01	99.96
123.0-124.0	0.00	146.71	0.00	99.77	170.0-171.0	0.01	147.00	0.01	99.97
124.0-125.0	0.00	146.71	0.00	99.77	171.0-172.0	0.01	147.01	0.01	99.97
125.0-126.0	0.00	146.71	0.00	99.77	172.0-173.0	0.01	147.02	0.01	99.98
126.0-127.0	0.00	146.71	0.00	99.77	173.0-174.0	0.01	147.03	0.01	99.98
127.0-128.0	0.00	146.71	0.00	99.77	174.0-175.0	0.01	147.03	0.00	99.99
128.0-129.0	0.00	146.71	0.00	99.77	175.0-176.0	0.01	147.04	0.00	99.99
129.0-130.0	0.00	146.71	0.00	99.77	176.0-177.0	0.00	147.04	0.00	99.99
130.0-131.0	0.00	146.71	0.00	99.77	177.0-178.0	0.00	147.05	0.00	100.00
131.0-132.0	0.00	146.71	0.00	99.77	178.0-179.0	0.00	147.05	0.00	100.00
132.0-133.0	0.00	146.71	0.00	99.77	179.0-180.0	0.00	147.05	0.00	100.00
133.0-134.0	0.00	146.71	0.00	99.77					
134.0-135.0	0.00	146.71	0.00	99.77					
135.0-136.0	0.00	146.71	0.00	99.77					
136.0-137.0	0.00	146.71	0.00	99.77					
137.0-138.0	0.00	146.71	0.00	99.77					
138.0-139.0	0.00	146.71	0.00	99.77					
139.0-140.0	0.00	146.71	0.00	99.77					
140.0-141.0	0.00	146.71	0.00	99.77					

Rectangle ISO Lighting Intensity Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03




Maximum Light Intensity(cd): 984.41

Maximum Cand.@Angle: H=1.0°,V=0.0°

Plane ISO-Illuminance Diagram

Lum. Name:55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03

Plane ISO-Illuminance Curve




Working Plane Luminaire Mounting Height(m): 3.00
Working Plane Maximum Illuminance(lx): 109.33
Working Plane Maximum Illuminance Position(d/h):H0.0 V0.0

3D Plane ISO Illuminance Diagram

Lum. Name: 55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03


3D Plane Illuminance Modal



Space ISO Illuminance Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03


Space ISO Illuminance Curve



Space Plane Maximum Illuminance and @Angle:983.96lx,1.0deg
Plane Maximum Lighting Intensity and @Angle:984.407cd,0deg

Illuminance-Distance Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03



Indoor Luminance Limiting Curves

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama (deg)	45	50	55	60	65	70	75	80	85
C0	3598	2792	2054	1298	651	0	0	0	0
C90	3531	2629	1887	1186	531	0	0	0	0

Luminance Limiting Curve




Luminous Size: Length(m)=-0.050 Width(m)=-0.050 Height(m)=0.000 Area(m^2)=0.001963

Luminous Type: Without Luminous Side

Luminous Curves: C0-C180 Color: C90-C270 Color:

Indoor Budgetary Estimate Table

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03



Indoor Coefficient of Utilization Table

Lum. Name:55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	115	113	111	109	113	111	109	108	107	106	104	103	102	101	100	99	98	97
2	111	108	105	102	109	106	104	101	103	101	99	100	98	97	97	96	95	93
3	108	103	100	97	106	102	99	96	100	97	95	97	95	93	95	93	92	91
4	105	99	96	93	103	98	95	92	96	93	91	95	92	90	93	91	89	88
5	102	96	92	89	100	95	92	89	94	90	88	92	89	87	91	88	87	85
6	99	93	89	86	98	92	89	86	91	88	85	90	87	85	89	86	84	83
7	97	90	86	83	95	90	86	83	89	85	83	88	85	82	87	84	82	81
8	94	88	84	81	93	87	84	81	86	83	81	86	83	80	85	82	80	79
9	92	86	82	79	91	85	82	79	84	81	79	84	81	79	83	80	78	77
10	90	84	80	77	89	83	80	77	83	79	77	82	79	77	81	79	77	76

Unified Glare Rating Table

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2020/06/03

Unified Glare Rating Table

Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	8.3	9.2	8.7	9.5	9.9	8.6	9.5	9.0	9.9	10.2
	Y=3H	8.1	8.9	8.5	9.3	9.7	8.4	9.3	8.8	9.6	10.0
	Y=4H	8.0	8.8	8.4	9.1	9.5	8.3	9.1	8.7	9.4	9.8
	Y=6H	7.9	8.6	8.3	9.0	9.4	8.2	8.9	8.6	9.3	9.7
	Y=8H	7.9	8.5	8.3	8.9	9.3	8.2	8.8	8.6	9.2	9.6
	Y=12H	7.8	8.4	8.2	8.8	9.2	8.1	8.7	8.5	9.1	9.5
X=4H	Y=2H	8.1	8.9	8.5	9.2	9.6	8.5	9.2	8.9	9.6	10.0
	Y=3H	7.9	8.5	8.4	9.0	9.4	8.3	8.9	8.7	9.3	9.7
	Y=4H	7.8	8.4	8.3	8.8	9.2	8.1	8.7	8.6	9.1	9.6
	Y=6H	7.7	8.2	8.2	8.6	9.1	8.0	8.5	8.5	8.9	9.4
	Y=8H	7.6	8.0	8.1	8.5	9.0	8.0	8.4	8.4	8.8	9.3
	Y=12H	7.6	7.9	8.0	8.4	8.9	7.9	8.3	8.4	8.8	9.2
X=8H	Y=4H	7.6	8.0	8.1	8.5	9.0	8.0	8.4	8.4	8.8	9.3
	Y=6H	7.5	7.8	8.0	8.3	8.9	7.8	8.2	8.3	8.7	9.2
	Y=8H	7.4	7.7	8.0	8.2	8.7	7.8	8.1	8.3	8.6	9.1
	Y=12H	7.4	7.6	7.9	8.1	8.7	7.7	8.0	8.2	8.5	9.0
X=12H	Y=4H	7.6	7.9	8.0	8.4	8.9	7.9	8.3	8.4	8.8	9.2
	Y=6H	7.4	7.7	8.0	8.2	8.7	7.8	8.1	8.3	8.5	9.1
	Y=8H	7.4	7.6	7.9	8.1	8.7	7.7	8.0	8.2	8.5	9.0
Variations with the objverver position at spacings											
S=1.0H		0.0/0.0					0.0/0.0				
S=1.5H		0.0/0.0					0.0/0.0				
S=2.0H		8.4/0.0					7.9/0.0				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		0.1					0.1				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

IES Indoor Report

Photometric Filename:UL-1001-0300-B-30度.IES

Candela Tabulation

V/H	C0. 0	C30. 0	C60. 0	C90. 0	C120. 0	C150. 0	C180. 0	C210. 0	C240. 0	C270. 0	C300. 0	C330. 0
γ 0. 0	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41	964. 41
γ 1. 0	984. 41	971. 47	964. 73	960. 59	957. 79	956. 01	972. 58	955. 90	944. 25	940. 48	936. 02	939. 72
γ 2. 0	976. 75	965. 61	961. 27	957. 85	955. 61	951. 06	950. 15	931. 23	917. 97	915. 18	909. 95	917. 64
γ 3. 0	958. 78	948. 77	948. 66	946. 08	943. 62	935. 08	917. 55	896. 23	878. 62	876. 44	872. 08	883. 36
γ 4. 0	929. 65	921. 26	923. 71	920. 35	920. 43	906. 52	870. 53	847. 58	826. 17	824. 40	822. 39	837. 21
γ 5. 0	885. 75	878. 64	884. 75	883. 06	883. 06	866. 26	810. 65	786. 31	762. 30	761. 37	760. 89	778. 40
γ 6. 0	828. 04	822. 19	832. 50	833. 70	834. 38	814. 47	739. 96	714. 99	688. 76	688. 73	691. 21	708. 36
γ 7. 0	758. 63	756. 10	771. 26	772. 46	773. 84	751. 55	661. 42	635. 36	608. 46	611. 79	614. 38	631. 23
γ 8. 0	681. 35	682. 97	701. 15	701. 62	702. 71	679. 77	579. 16	551. 74	526. 84	532. 40	534. 52	550. 87
γ 9. 0	599. 30	606. 97	626. 61	624. 84	624. 51	601. 85	497. 71	470. 35	448. 41	454. 58	455. 76	470. 81
γ 10. 0	516. 55	526. 94	548. 02	545. 45	544. 77	522. 38	418. 93	393. 74	374. 46	381. 12	382. 40	394. 41
γ 11. 0	435. 56	447. 36	469. 36	467. 54	466. 91	444. 26	347. 21	324. 66	308. 18	314. 39	314. 86	326. 14
γ 12. 0	362. 39	372. 82	393. 06	393. 91	393. 38	370. 91	283. 46	265. 50	250. 92	255. 87	255. 99	266. 68
γ 13. 0	298. 22	306. 56	323. 71	326. 30	326. 49	304. 84	230. 77	216. 18	203. 96	206. 77	206. 67	215. 90
γ 14. 0	242. 95	250. 48	264. 89	267. 90	267. 91	248. 79	187. 27	175. 03	165. 04	166. 50	166. 72	174. 05
γ 15. 0	197. 11	204. 33	215. 69	218. 46	218. 59	202. 64	151. 66	141. 72	133. 30	134. 70	135. 02	140. 40
γ 16. 0	160. 24	166. 11	174. 96	177. 37	177. 99	165. 22	122. 76	114. 51	107. 70	108. 70	109. 60	114. 45
γ 17. 0	130. 09	134. 89	142. 02	143. 15	144. 20	134. 66	99. 92	92. 68	87. 38	88. 19	88. 97	93. 75
γ 18. 0	106. 18	109. 61	115. 56	116. 07	117. 00	109. 93	82. 14	75. 47	71. 35	71. 86	72. 74	77. 20
γ 19. 0	87. 41	89. 44	94. 57	94. 67	95. 88	90. 21	68. 56	62. 51	59. 20	59. 19	59. 65	63. 94
γ 20. 0	72. 36	73. 64	77. 99	78. 12	79. 43	75. 03	57. 77	52. 78	49. 97	49. 85	49. 87	53. 60
γ 21. 0	60. 55	61. 26	65. 28	65. 03	66. 60	63. 24	49. 47	45. 25	42. 94	42. 62	42. 49	45. 66
γ 22. 0	51. 39	51. 91	55. 18	54. 99	56. 62	53. 84	42. 76	39. 22	37. 25	36. 84	36. 87	39. 23
γ 23. 0	44. 07	44. 67	47. 38	46. 92	48. 37	46. 32	37. 28	34. 40	32. 67	32. 20	32. 23	34. 06
γ 24. 0	38. 22	38. 81	41. 23	40. 34	41. 50	40. 21	32. 70	30. 16	28. 89	28. 34	28. 34	29. 91
γ 25. 0	33. 41	33. 78	36. 00	35. 07	35. 85	35. 05	28. 90	26. 62	25. 60	25. 05	24. 92	26. 41
γ 26. 0	29. 38	29. 49	31. 46	30. 60	31. 19	30. 66	25. 70	23. 73	22. 73	22. 20	22. 09	23. 39
γ 27. 0	25. 87	25. 96	27. 40	26. 76	27. 35	27. 02	22. 99	21. 37	20. 30	19. 85	19. 75	20. 76
γ 28. 0	22. 94	22. 97	24. 07	23. 62	24. 14	23. 98	20. 68	19. 25	18. 24	17. 90	17. 74	18. 58
γ 29. 0	20. 49	20. 52	21. 36	20. 91	21. 40	21. 35	18. 70	17. 42	16. 46	16. 16	16. 04	16. 69
γ 30. 0	18. 38	18. 37	19. 04	18. 72	19. 15	19. 14	16. 85	15. 82	14. 87	14. 65	14. 57	15. 09
γ 31. 0	16. 54	16. 55	17. 06	16. 82	17. 15	17. 18	15. 31	14. 40	13. 46	13. 32	13. 19	13. 62
γ 32. 0	15. 02	14. 92	15. 34	15. 18	15. 40	15. 50	13. 92	13. 13	12. 21	12. 13	12. 02	12. 36
γ 33. 0	13. 62	13. 55	13. 83	13. 71	13. 93	14. 04	12. 69	11. 94	11. 14	11. 03	10. 95	11. 24
γ 34. 0	12. 35	12. 24	12. 54	12. 43	12. 63	12. 85	11. 60	10. 94	10. 19	10. 05	9. 95	10. 27
γ 35. 0	11. 22	11. 09	11. 41	11. 27	11. 46	11. 71	10. 61	10. 02	9. 34	9. 17	9. 07	9. 39
γ 36. 0	10. 23	10. 07	10. 38	10. 27	10. 44	10. 70	9. 76	9. 22	8. 56	8. 38	8. 32	8. 56
γ 37. 0	9. 35	9. 18	9. 45	9. 38	9. 53	9. 65	9. 02	8. 50	7. 84	7. 70	7. 59	7. 82
γ 38. 0	8. 53	8. 39	8. 59	8. 59	8. 72	8. 83	8. 36	7. 86	7. 19	7. 08	6. 98	7. 16
γ 39. 0	7. 84	7. 70	7. 86	7. 88	8. 01	8. 11	7. 73	7. 32	6. 62	6. 54	6. 45	6. 56
γ 40. 0	7. 22	7. 11	7. 22	7. 25	7. 38	7. 49	7. 20	6. 80	6. 12	6. 09	5. 97	6. 05
γ 41. 0	6. 70	6. 58	6. 68	6. 68	6. 81	6. 89	6. 68	6. 32	5. 66	5. 63	5. 54	5. 62
γ 42. 0	6. 19	6. 10	6. 16	6. 19	6. 29	6. 38	6. 21	5. 84	5. 30	5. 20	5. 11	5. 21
γ 43. 0	5. 74	5. 66	5. 72	5. 73	5. 82	5. 89	5. 78	5. 44	4. 92	4. 85	4. 78	4. 83
γ 44. 0	5. 35	5. 25	5. 30	5. 32	5. 36	5. 43	5. 36	5. 06	4. 55	4. 52	4. 44	4. 46
γ 45. 0	5. 00	4. 88	4. 90	4. 90	4. 97	5. 02	4. 95	4. 69	4. 23	4. 21	4. 11	4. 15
γ 46. 0	4. 64	4. 53	4. 55	4. 55	4. 59	4. 65	4. 57	4. 34	3. 93	3. 90	3. 81	3. 83

Candela Tabulation - (Cont.)

V/H	C0. 0	C30. 0	C60. 0	C90. 0	C120. 0	C150. 0	C180. 0	C210. 0	C240. 0	C270. 0	C300. 0	C330. 0
γ 47. 0	4. 33	4. 20	4. 23	4. 22	4. 24	4. 34	4. 20	3. 99	3. 65	3. 60	3. 53	3. 56
γ 48. 0	4. 02	3. 89	3. 91	3. 91	3. 91	4. 01	3. 89	3. 69	3. 38	3. 33	3. 25	3. 29
γ 49. 0	3. 75	3. 61	3. 62	3. 59	3. 61	3. 73	3. 59	3. 41	3. 12	3. 08	3. 01	3. 04
γ 50. 0	3. 52	3. 35	3. 34	3. 32	3. 34	3. 46	3. 30	3. 15	2. 89	2. 82	2. 76	2. 80
γ 51. 0	3. 27	3. 11	3. 09	3. 06	3. 09	3. 21	3. 04	2. 88	2. 67	2. 60	2. 53	2. 57
γ 52. 0	3. 02	2. 88	2. 84	2. 81	2. 84	2. 89	2. 77	2. 64	2. 42	2. 38	2. 30	2. 33
γ 53. 0	2. 77	2. 64	2. 58	2. 57	2. 60	2. 64	2. 53	2. 42	2. 20	2. 15	2. 10	2. 10
γ 54. 0	2. 55	2. 41	2. 36	2. 34	2. 37	2. 40	2. 29	2. 19	1. 98	1. 94	1. 89	1. 89
γ 55. 0	2. 31	2. 17	2. 12	2. 13	2. 16	2. 15	2. 07	1. 96	1. 78	1. 74	1. 68	1. 69
γ 56. 0	2. 09	1. 96	1. 90	1. 92	1. 93	1. 93	1. 85	1. 76	1. 59	1. 55	1. 48	1. 50
γ 57. 0	1. 87	1. 74	1. 70	1. 72	1. 72	1. 73	1. 64	1. 55	1. 41	1. 36	1. 30	1. 33
γ 58. 0	1. 66	1. 53	1. 51	1. 54	1. 54	1. 53	1. 45	1. 36	1. 23	1. 18	1. 13	1. 16
γ 59. 0	1. 45	1. 35	1. 34	1. 34	1. 34	1. 33	1. 25	1. 18	1. 05	1. 02	0. 98	0. 99
γ 60. 0	1. 27	1. 19	1. 17	1. 16	1. 17	1. 16	1. 08	1. 01	0. 91	0. 87	0. 82	0. 85
γ 61. 0	1. 11	1. 03	1. 00	1. 00	1. 00	0. 98	0. 90	0. 85	0. 75	0. 71	0. 68	0. 70
γ 62. 0	0. 95	0. 88	0. 85	0. 85	0. 83	0. 83	0. 76	0. 71	0. 59	0. 58	0. 54	0. 57
γ 63. 0	0. 80	0. 72	0. 70	0. 71	0. 70	0. 68	0. 61	0. 56	0. 47	0. 45	0. 41	0. 44
γ 64. 0	0. 67	0. 58	0. 56	0. 58	0. 56	0. 55	0. 47	0. 44	0. 34	0. 33	0. 31	0. 33
γ 65. 0	0. 54	0. 46	0. 43	0. 44	0. 43	0. 40	0. 34	0. 30	0. 23	0. 21	0. 18	0. 22
γ 66. 0	0. 41	0. 34	0. 31	0. 32	0. 32	0. 28	0. 23	0. 20	0. 12	0. 10	0. 09	0. 10
γ 67. 0	0. 28	0. 23	0. 20	0. 22	0. 20	0. 17	0. 13	0. 09	0. 00	0. 00	0. 00	0. 00
γ 68. 0	0. 18	0. 14	0. 11	0. 10	0. 09	0. 05	0. 01	0. 01	0. 00	0. 00	0. 00	0. 00
γ 69. 0	0. 09	0. 03	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 70. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 71. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 72. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 73. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 74. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 75. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 76. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 77. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 78. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 79. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 80. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 81. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 82. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 83. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 84. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 85. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 86. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 87. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 88. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 89. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 90. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 91. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 92. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 93. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00

Photometric Filename:UL-1001-0300-B-30度.IES

Candela Tabulation - (Cont.)

[illegible]

Candela Tabulation - (Cont.)

V/H	C0.0	C30.0	C60.0	C90.0	C120.0	C150.0	C180.0	C210.0	C240.0	C270.0	C300.0	C330.0
γ 141.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 142.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 143.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 144.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 145.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 146.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 147.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 148.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 149.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
γ 150.0	0.00	0.00	0.00	0.00	0.00	0.00	0.07	0.04	0.00	0.00	0.00	0.00
γ 151.0	0.00	0.00	0.00	0.00	0.00	0.00	0.15	0.11	0.05	0.05	0.05	0.05
γ 152.0	0.02	0.00	0.00	0.00	0.00	0.00	0.21	0.19	0.12	0.12	0.10	0.09
γ 153.0	0.09	0.05	0.00	0.00	0.00	0.00	0.27	0.25	0.19	0.17	0.19	0.17
γ 154.0	0.15	0.11	0.05	0.02	0.03	0.04	0.33	0.31	0.25	0.23	0.23	0.23
γ 155.0	0.22	0.19	0.10	0.09	0.09	0.11	0.41	0.37	0.30	0.28	0.29	0.28
γ 156.0	0.28	0.25	0.17	0.16	0.16	0.18	0.46	0.42	0.39	0.34	0.35	0.35
γ 157.0	0.33	0.31	0.24	0.22	0.23	0.24	0.52	0.48	0.46	0.39	0.41	0.39
γ 158.0	0.40	0.37	0.29	0.28	0.27	0.30	0.57	0.52	0.50	0.43	0.44	0.44
γ 159.0	0.46	0.43	0.34	0.33	0.34	0.36	0.62	0.56	0.55	0.47	0.49	0.48
γ 160.0	0.51	0.49	0.40	0.39	0.39	0.41	0.65	0.59	0.58	0.50	0.51	0.53
γ 161.0	0.54	0.53	0.45	0.43	0.44	0.46	0.68	0.63	0.61	0.52	0.55	0.56
γ 162.0	0.59	0.58	0.49	0.47	0.48	0.50	0.70	0.65	0.61	0.53	0.56	0.58
γ 163.0	0.62	0.61	0.52	0.51	0.51	0.54	0.74	0.67	0.63	0.56	0.59	0.60
γ 164.0	0.66	0.63	0.55	0.54	0.55	0.57	0.75	0.69	0.65	0.57	0.59	0.61
γ 165.0	0.68	0.68	0.58	0.57	0.57	0.58	0.77	0.70	0.66	0.57	0.60	0.63
γ 166.0	0.70	0.69	0.59	0.58	0.58	0.61	0.78	0.71	0.66	0.58	0.60	0.63
γ 167.0	0.71	0.70	0.61	0.60	0.60	0.63	0.79	0.71	0.67	0.57	0.60	0.63
γ 168.0	0.73	0.72	0.61	0.60	0.62	0.64	0.78	0.70	0.66	0.59	0.59	0.62
γ 169.0	0.74	0.73	0.63	0.61	0.62	0.64	0.78	0.69	0.65	0.57	0.59	0.63
γ 170.0	0.72	0.72	0.63	0.62	0.63	0.63	0.77	0.68	0.63	0.57	0.58	0.60
γ 171.0	0.72	0.73	0.63	0.62	0.62	0.64	0.75	0.68	0.63	0.55	0.56	0.59
γ 172.0	0.71	0.71	0.62	0.60	0.61	0.63	0.75	0.65	0.62	0.55	0.55	0.57
γ 173.0	0.71	0.70	0.62	0.60	0.61	0.61	0.73	0.63	0.60	0.54	0.54	0.57
γ 174.0	0.69	0.68	0.61	0.58	0.60	0.60	0.72	0.63	0.60	0.54	0.55	0.55
γ 175.0	0.69	0.67	0.59	0.58	0.58	0.58	0.71	0.63	0.60	0.53	0.54	0.54
γ 176.0	0.67	0.67	0.58	0.57	0.58	0.57	0.70	0.61	0.60	0.54	0.55	0.54
γ 177.0	0.67	0.66	0.57	0.57	0.56	0.57	0.70	0.61	0.60	0.52	0.53	0.55
γ 178.0	0.67	0.65	0.57	0.56	0.56	0.56	0.70	0.62	0.62	0.54	0.54	0.56
γ 179.0	0.67	0.65	0.56	0.55	0.56	0.56	0.70	0.62	0.62	0.54	0.56	0.55
γ 180.0	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61