

SIMATIC S7-300, CPU 312 Central processing unit with MPI, Integr. power supply
24 V DC, Work memory 32 KB, Micro Memory Card required

| General information | |
|---|---|
| Product type designation | CPU 312 |
| HW functional status | 01 |
| Firmware version | V3.3 |
| Engineering with | |
| • Programming package | STEP 7 V5.5 + SP1 or higher or STEP 7 V5.2 + SP1 or higher with HSP 218 |
| Supply voltage | |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| external protection for power supply lines (recommendation) | 2 A min. |
| Mains buffering | |
| • Mains/voltage failure stored energy time | 5 ms |
| • Repeat rate, min. | 1 s |
| Input current | |
| Current consumption (rated value) | 650 mA |
| Current consumption (in no-load operation), typ. | 140 mA |
| Inrush current, typ. | 3.5 A |
| I ² t | 1 A ² ·s |
| Power loss | |
| Power loss, typ. | 4 W |
| Memory | |
| Work memory | |
| • integrated | 32 kbyte |
| • expandable | No |
| Load memory | |
| • Plug-in (MMC) | Yes |
| • Plug-in (MMC), max. | 8 Mbyte |
| • Data management on MMC (after last programming), min. | 10 a |
| Backup | |
| • present | Yes; Guaranteed by MMC (maintenance-free) |
| • without battery | Yes; Program and data |
| CPU processing times | |
| for bit operations, typ. | 0.1 µs |
| for word operations, typ. | 0.24 µs |
| for fixed point arithmetic, typ. | 0.32 µs |
| for floating point arithmetic, typ. | 1.1 µs |
| CPU-blocks | |
| Number of blocks (total) | 1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used. |
| DB | |
| • Number, max. | 1 024; Number range: 1 to 16000 |
| • Size, max. | 32 kbyte |
| FB | |
| • Number, max. | 1 024; Number range: 0 to 7999 |
| • Size, max. | 32 kbyte |
| FC | |
| • Number, max. | 1 024; Number range: 0 to 7999 |
| • Size, max. | 32 kbyte |
| OB | |

| | |
|---|--|
| • Number, max. | see instruction list |
| • Size, max. | 32 kbyte |
| • Number of free cycle OBs | 1; OB 1 |
| • Number of time alarm OBs | 1; OB 10 |
| • Number of delay alarm OBs | 2; OB 20, 21 |
| • Number of cyclic interrupt OBs | 4; OB 32, 33, 34, 35 |
| • Number of process alarm OBs | 1; OB 40 |
| • Number of startup OBs | 1; OB 100 |
| • Number of asynchronous error OBs | 4; OB 80, 82, 85, 87 |
| • Number of synchronous error OBs | 2; OB 121, 122 |
| Nesting depth | |
| • per priority class | 16 |
| • additional within an error OB | 4 |
| Counters, timers and their retentivity | |
| S7 counter | |
| • Number | 256 |
| Retentivity | |
| — adjustable | Yes |
| — preset | Z 0 to Z 7 |
| Counting range | |
| — lower limit | 0 |
| — upper limit | 999 |
| IEC counter | |
| • present | Yes |
| • Type | SFB |
| • Number | Unlimited (limited only by RAM capacity) |
| S7 times | |
| • Number | 256 |
| Retentivity | |
| — adjustable | Yes |
| — preset | No retentivity |
| Time range | |
| — lower limit | 10 ms |
| — upper limit | 9 990 s |
| IEC timer | |
| • present | Yes |
| • Type | SFB |
| • Number | Unlimited (limited only by RAM capacity) |
| Data areas and their retentivity | |
| Retentive data area (incl. timers, counters, flags), max. | 32 kbyte |
| Flag | |
| • Size, max. | 256 byte |
| • Retentivity available | Yes; MB 0 to MB 255 |
| • Retentivity preset | MB 0 to MB 15 |
| • Number of clock memories | 8; 1 memory byte |
| Data blocks | |
| • Retentivity adjustable | Yes; via non-retain property on DB |
| • Retentivity preset | Yes |
| Local data | |
| • per priority class, max. | 32 kbyte; Max. 2 KB per block |
| Address area | |
| I/O address area | |
| • Inputs | 1 024 byte |
| • Outputs | 1 024 byte |
| Process image | |
| • Inputs | 1 024 byte |
| • Outputs | 1 024 byte |
| • Inputs, adjustable | 1 024 byte |
| • Outputs, adjustable | 1 024 byte |
| • Inputs, default | 128 byte |

| | |
|---|---|
| • Outputs, default | 128 byte |
| Digital channels | |
| • Inputs | 256 |
| — of which central | 256 |
| • Outputs | 256 |
| — of which central | 256 |
| Analog channels | |
| • Inputs | 64 |
| — of which central | 64 |
| • Outputs | 64 |
| — of which central | 64 |
| Hardware configuration | |
| Number of expansion units, max. | 0 |
| Number of DP masters | |
| • integrated | 0 |
| • via CP | 4 |
| Number of operable FMs and CPs (recommended) | |
| • FM | 8 |
| • CP, PtP | 8 |
| • CP, LAN | 4 |
| Rack | |
| • Racks, max. | 1 |
| • Modules per rack, max. | 8 |
| Time of day | |
| Clock | |
| • Software clock | Yes |
| • retentive and synchronizable | No; Buffered: No, Can be synchronized: Yes |
| • Deviation per day, max. | 10 s; Typ.: 2 s |
| • Behavior of the clock following POWER-ON | the clock continues at the time of day it had when power was switched off |
| Operating hours counter | |
| • Number | 1 |
| • Number/Number range | 0 |
| • Range of values | 0 to 2 ³¹ hours (when using SFC 101) |
| • Granularity | 1 h |
| • retentive | Yes; Must be restarted at each restart |
| Clock synchronization | |
| • supported | Yes |
| • to MPI, master | Yes |
| • on MPI, device | Yes |
| • in AS, master | Yes |
| • in AS, device | No |
| Digital inputs | |
| Number of digital inputs | 0 |
| Digital outputs | |
| Number of digital outputs | 0 |
| Analog inputs | |
| Number of analog inputs | 0 |
| Interfaces | |
| Number of PROFINET interfaces | 0 |
| Number of RS 485 interfaces | 1; MPI |
| Number of RS 422 interfaces | 0 |
| 1. Interface | |
| Interface type | Integrated RS 485 interface |
| Isolated | No |
| Interface types | |
| • RS 485 | Yes |
| • Output current of the interface, max. | 200 mA |
| Protocols | |
| • MPI | Yes |
| • PROFIBUS DP master | No |

| | |
|--|--|
| • PROFIBUS DP device | No |
| • Point-to-point connection | No |
| MPI | |
| • Transmission rate, max. | 187.5 kbit/s |
| Services | |
| — PG/OP communication | Yes |
| — Routing | No |
| — Global data communication | Yes |
| — S7 basic communication | Yes |
| — S7 communication | Yes; Only server, configured on one side |
| — S7 communication, as client | No |
| — S7 communication, as server | Yes |
| Protocols | |
| PROFIsafe | No |
| communication functions / header | |
| PG/OP communication | Yes |
| Data record routing | No |
| Global data communication | |
| • supported | Yes |
| • Number of GD loops, max. | 8 |
| • Number of GD packets, max. | 8 |
| • Number of GD packets, transmitter, max. | 8 |
| • Number of GD packets, receiver, max. | 8 |
| • Size of GD packets, max. | 22 byte |
| • Size of GD packet (of which consistent), max. | 22 byte |
| S7 basic communication | |
| • supported | Yes |
| • User data per job, max. | 76 byte |
| • User data per job (of which consistent), max. | 76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server) |
| S7 communication | |
| • supported | Yes |
| • as server | Yes |
| • as client | Yes; Via CP and loadable FB |
| • User data per job, max. | 180 byte; With PUT/GET |
| • User data per job (of which consistent), max. | 240 byte; as server |
| S5 compatible communication | |
| • supported | Yes; via CP and loadable FC |
| Number of connections | |
| • overall | 6 |
| • usable for PG communication | 5 |
| — reserved for PG communication | 1 |
| — adjustable for PG communication, min. | 1 |
| — adjustable for PG communication, max. | 5 |
| • usable for OP communication | 5 |
| — reserved for OP communication | 1 |
| — adjustable for OP communication, min. | 1 |
| — adjustable for OP communication, max. | 5 |
| • usable for S7 basic communication | 2 |
| — reserved for S7 basic communication | 0 |
| — adjustable for S7 basic communication, min. | 0 |
| — adjustable for S7 basic communication, max. | 2 |
| S7 message functions | |
| Number of login stations for message functions, max. | 6; Depending on the configured connections for PG/OP and S7 basic communication |
| Process diagnostic messages | Yes |
| simultaneously active Alarm_S blocks, max. | 300 |
| Test commissioning functions | |
| Status block | Yes; Up to 2 simultaneously |
| Single step | Yes |
| Number of breakpoints | 4 |

| | | | |
|--|--------|---|----------------|
| Status/control | | | |
| <ul style="list-style-type: none">• Status/control variable | | Yes | |
| <ul style="list-style-type: none">• Variables | | Inputs, outputs, memory bits, DB, times, counters | |
| <ul style="list-style-type: none">• Number of variables, max. | | 30 | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— of which status variables, max. | | 30 | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— of which control variables, max. | | 14 | |
| Forcing | | | |
| <ul style="list-style-type: none">• Forcing | | Yes | |
| <ul style="list-style-type: none">• Forcing, variables | | Inputs, outputs | |
| <ul style="list-style-type: none">• Number of variables, max. | | 10 | |
| Diagnostic buffer | | | |
| <ul style="list-style-type: none">• present | | Yes | |
| <ul style="list-style-type: none">• Number of entries, max. | | 500 | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— adjustable | | No | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— of which powerfail-proof | | 100; Only the last 100 entries are retained | |
| <ul style="list-style-type: none">• Number of entries readable in RUN, max. | | 499 | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— adjustable | | Yes; From 10 to 499 | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— preset | | 10 | |
| Service data | | | |
| <ul style="list-style-type: none">• can be read out | | Yes | |
| Ambient conditions | | | |
| Ambient temperature during operation | | | |
| <ul style="list-style-type: none">• min. | | 0 °C | |
| <ul style="list-style-type: none">• max. | | 60 °C | |
| configuration / header | | | |
| Configuration software | | | |
| <ul style="list-style-type: none">• STEP 7 | | Yes; V5.2 SP1 or higher with HW update | |
| configuration / programming / header | | | |
| <ul style="list-style-type: none">• Command set | | see instruction list | |
| <ul style="list-style-type: none">• Nesting levels | | 8 | |
| <ul style="list-style-type: none">• System functions (SFC) | | see instruction list | |
| <ul style="list-style-type: none">• System function blocks (SFB) | | see instruction list | |
| Programming language | | | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— LAD | | Yes | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— FBD | | Yes | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— STL | | Yes | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— SCL | | Yes | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— GRAPH | | Yes | |
| <ul style="list-style-type: none"><ul style="list-style-type: none">— HiGraph® | | Yes | |
| Know-how protection | | | |
| <ul style="list-style-type: none">• User program protection/password protection | | Yes | |
| <ul style="list-style-type: none">• Block encryption | | Yes; With S7 block Privacy | |
| Dimensions | | | |
| Width | | 40 mm | |
| Height | | 125 mm | |
| Depth | | 130 mm | |
| Weights | | | |
| Weight, approx. | | 270 g | |
| Classifications | | | |
| | | Version | Classification |
| | eClass | 14 | 27-24-22-07 |
| | eClass | 12 | 27-24-22-07 |
| | eClass | 9.1 | 27-24-22-07 |
| | eClass | 9 | 27-24-22-07 |
| | eClass | 8 | 27-24-22-07 |
| | eClass | 7.1 | 27-24-22-07 |
| | eClass | 6 | 27-24-22-07 |
| | ETIM | 9 | EC000236 |

| | | |
|--------|----|-------------|
| ETIM | 8 | EC000236 |
| ETIM | 7 | EC000236 |
| IDEA | 4 | 3565 |
| UNSPSC | 15 | 32-15-17-05 |

| |
|--------------------------|
| Approvals / Certificates |
| General Product Approval |

| | | | |
|--------------------------|-----|-------------------|-------------------|
| General Product Approval | EMV | Test Certificates | Marine / Shipping |
|--------------------------|-----|-------------------|-------------------|

[Miscellaneous](#)

[Miscellaneous](#)

[Special Test Certificate](#)

| | |
|-------------------|-------|
| Marine / Shipping | other |
|-------------------|-------|

[Miscellaneous](#)

[Confirmation](#)

| | |
|---------|-------------|
| Railway | Environment |
|---------|-------------|

[Special Test Certificate](#)

[Confirmation](#)

[Environmental Confirmations](#)

[Environmental Confirmations](#)

last modified:

4/7/2025 