



Product Service

Attestation of Conformity

No. N8A 121865 0002 Rev. 00

Holder of Attestation: **Jiangxi Huntect Electrical Technology Co., Ltd**

No.1829 Yangguang Avenue, High-tech Development Zone
338000 Xinyu City, Jiangxi Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Terminal block**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105233111601

Date, 2023-08-16

(Martin Ma)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**



Product Service

Attestation of Conformity

No. N8A 121865 0002 Rev. 00

Model(s): RES-P-10/25-B-30-BK, RES-P-10/25-B-30-OG,
RES-P-10/25-B-30(S)-BK, RES-P-10/25-B-30(S)-OG,
RES-P-35/70-B-30-BK, RES-P-35/70-B-30-OG,
RES-P-35/70-B-30(S)-BK, RES-P-35/70-B-30(S)-OG

Parameters:

Rated impulse withstand voltage (U_{imp}):	8kV
Ability to receive conductors:	Rigid / stranded / flexible (prepared conductor, with lug)
Type of clamping units:	Screw-type
Number of clamping units:	1
Number of poles:	1
Method of fixing:	Fix with screw

Model	Rated insulation voltage U_i (VDC)	Conventional free air thermal current I_{th} (A)	Rated connection capacity (mm ²)	Rated cross-section (mm ²)
RES-P-10/25-B-30-BK	1500	120	10 - 25	25
RES-P-10/25-B-30-OG	1500	120	10 - 25	25
RES-P-10/25-B-30(S)-BK	1500	120	10 - 25	25
RES-P-10/25-B-30(S)-OG	1500	120	10 - 25	25
RES-P-35/70-B-30-BK	1500	250	35 - 70	70
RES-P-35/70-B-30-OG	1500	250	35 - 70	70
RES-P-35/70-B-30(S)-BK	1500	250	35 - 70	70
RES-P-35/70-B-30(S)-OG	1500	250	35 - 70	70

Tested according to: EN 60947-7-1:2009
EN 60947-1:2007/A2:2014
EN IEC 60947-1:2021

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®