

STL TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

TEST OBJECT Oil immersed power transformer

DESIGNATION S-500/11
3 phases 500 kVA 11/0.4 kV 50 Hz Dyn11

MANUFACTURER Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

TESTED FOR Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

DATE OF TESTS 2023-04-11 ~ 2023-05-02

TESTED BY Korea Electrotechnology Research Institute(KERI)
111, Hanggaul-ro, Sangnok-gu, Ansan-si, 15588, Republic of Korea

The test object, constructed complying with the description, essential drawings and photographs incorporated in this Certificate has been subjected to the series of proving tests strictly in accordance with

IEC 60076-1:2011, -2:2011, -3:2018, -5:2006

This STL Type Test Certificate has been issued by KERI following exclusively the STL Guides and Procedures. The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page No.4.

This Type Test Certificate applies only to the test object. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This Type Test Certificate comprises 50 sheets in total.

COPYRIGHT : Only integral reproduction of this 'TYPE TEST CERTIFICATE' is permitted without written permission from KERI. Electronic copies are information only. The sealed version of this 'TYPE TEST CERTIFICATE' is the only valid version.



President of KERI

강남호

Date of issue

2023-05-30

[DF-HH-7082-02/01]



STL TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

TEST OBJECT Oil immersed power transformer

DESIGNATION S-200/11
3 phases 200 kVA 11/0.4 kV 50 Hz Dyn11

MANUFACTURER Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

TESTED FOR Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

DATE OF TESTS 2023-04-11 ~ 2023-05-02

TESTED BY Korea Electrotechnology Research Institute(KERI)
111, Hanggaul-ro, Sangnok-gu, Ansan-si, 15588, Republic of Korea

The test object, constructed complying with the description, essential drawings and photographs incorporated in this Certificate has been subjected to the series of proving tests strictly in accordance with

IEC 60076-1:2011, -2:2011, -3:2018, -5:2006

This STL Type Test Certificate has been issued by KERI following exclusively the STL Guides and Procedures. The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page No.4.

This Type Test Certificate applies only to the test object. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This Type Test Certificate comprises 50 sheets in total.

COPYRIGHT : Only integral reproduction of this 'TYPE TEST CERTIFICATE' is permitted without written permission from KERI. Electronic copies are information only. The sealed version of this 'TYPE TEST CERTIFICATE' is the only valid version.



President of KERI

김남교

Date of issue

2023-05-30

[DF-HH-7082-02/01]



STL TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

TEST OBJECT Oil immersed power transformer

DESIGNATION S-300/11
3 phases 300 kVA 11/0.4 kV 50 Hz Dyn11

MANUFACTURER Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

TESTED FOR Zhejiang Jiangshan Yuanguang Electirc Co., Ltd.
No.1 Xinggong 8 Rd., Jiangshan, Zhejiang, China

DATE OF TESTS 2023-04-11 ~ 2023-05-02

TESTED BY Korea Electrotechnology Research Institute(KERI)
111, Hanggaul-ro, Sangnok-gu, Ansan-si, 15588, Republic of Korea

The test object, constructed complying with the description, essential drawings and photographs incorporated in this Certificate has been subjected to the series of proving tests strictly in accordance with

IEC 60076-1:2011, -2:2011, -3:2018, -5:2006

This STL Type Test Certificate has been issued by KERI following exclusively the STL Guides and Procedures. The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page No.4.

This Type Test Certificate applies only to the test object. The responsibility for conformity of any object having the same designations with that tested rests with the Manufacturer.

This Type Test Certificate comprises 50 sheets in total.

COPYRIGHT : Only integral reproduction of this 'TYPE TEST CERTIFICATE' is permitted without written permission from KERI. Electronic copies are information only. The sealed version of this 'TYPE TEST CERTIFICATE' is the only valid version.



President of KERI

김남교

Date of issue

2023-05-30

[DF-HH-7082-02/01]

