



Product Service

Attestation of Conformity

No. E8A 133390 0001 Rev. 00

Holder of Attestation: **Acrel Co., Ltd.**

No.253, Yulv Road, Jiading
201801 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Electronic measuring equipment
DC System Insulation Monitoring Device**

Model(s): For DC System Insulation Monitoring Device: AIM-D500-CA
For Coupling Device for Insulation Monitoring:
ACPD300

Description of Object: Rated input:

For Type AIM-D500-CA:
Rate voltage: $U_n = 50-400VDC$
Response value: $R_{an} = 1k-2M\Omega$
Supply voltage: $U_s = 100-277VAC$

Tested according to: For Type ACPD300:
Rate voltage: $U_n = 400-1000VDC$
EN IEC 61326-1:2021
EN IEC 61326-2-4:2021

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 4899925006400

Date, 2025-10-21


(Ming Gu)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.